

Information for boiler space heaters, boiler combination heaters and cogeneration space heaters

ENERTECH GROUP
Eneritech AB, 341 26 Ljungby

Model(s): CTC EcoMiniel 9kW								
Condensing boiler:		No		Built in DHW:		NA	Eff class:	D
Low-temperature (**) boiler:		No		Built in DHW:		NA	Controller	No
B1 boiler:		No		Built in DHW:		NA	Contribution:	0
Cogeneration space heater:		No	If yes, equipped with a supplementary heater:	NA	Package η_s	37		
Electrical boiler		Yes		Built in DHW:		No	Package class:	D
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Rated heat output	P_{rated}	9	kW	Seasonal space heating energy efficiency	η_s	37	%	
For boiler space heaters and boiler combination heaters: Useful heat output				For boiler space heaters and boiler combination heaters: Useful efficiency				
At rated heat output and high-temperature regime (*)	P_4	9,0	kW	At rated heat output and high-temperature regime (*)	η_4	39,56	%	
At 30 % of rated heat output and low-temperature regime (**)	P_1	NA	kW	At 30 % of rated heat output and low-temperature regime (**)	η_1	NA	%	
For cogeneration space heaters: Useful heat output				For cogeneration space heaters: Useful efficiency				
At rated heat output of cogeneration space heater with supplementary heater enabled	$P_{CHP100 + Sup0}$	NA	kW	At rated heat output of cogeneration space heater with supplementary heater disabled	$\eta_{CHP100 + Sup0}$	NA	%	
At rated heat output of cogeneration space heater with supplementary heater enabled	$P_{CHP100 + Sup100}$	NA	kW	At rated heat output of cogeneration space heater with supplementary heater enabled	$\eta_{CHP100 + Sup100}$	NA	%	
For cogeneration space heaters: Electrical efficiency				Supplementary heater				
At rated heat output of cogeneration space heater with supplementary heater disabled	$\eta_{el,CHP100 + Sup0}$	NA	%	Rated heat output	P_{sup}	NA	kW	
At rated heat output of cogeneration space heater with supplementary heater enabled	$\eta_{el,CHP100 + Sup100}$	NA	%	Type of energy input	NA			
Auxiliary electricity consumption				Other items				
At full load	el_{max}	NA	kW	Standby heat loss	P_{stby}	0,060	kW	
At part load	el_{min}	NA	kW	Ignition burner power consumption	P_{ign}	NA	kW	
In standby mode	P_{SB}	0,006	kW	Emissions of nitrogen oxides	NO_x	NA	mg/kWh	
For combination heaters:								
Declared load profile	NA			Water heating energy efficiency/Class	$\eta_{wh/Class}$	NA	%/-	
Daily electricity consumption	Q_{elec}	NA	1,0 kWh	Daily fuel consumption	Q_{fuel}	NA	1,0 kWh	
Contact details				Eneritech AB, Box 309, SE-341 26 Ljungby Tel +46 372 88000 www.ctc.se				

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet. (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).