



Valvoindustria Ing. Rizzio S.p.a.

Via Circonvallazione, 10 - 13018 Valduggia - Italy

Tel. +39 0163 47891 - Fax +39 0163 47895 - E-mail: info@vironline.com

Cap. Soc. €. 5.000.000,00 int. vers. - R.E.A. di Vercelli n. 102566 - Pos. Mecc. VC 000506

Reg. Impr. VC / Cod. Fisc. / P. IVA 00166310029



Declaration n. 02.03.EN

Valduggia, 01/04/2019

EU DECLARATION OF CONFORMITY

according to ISO/IEC 17050-1

VIR Valvoindustria Ing. Rizzio S.p.A.

a company with Quality Management System in compliance with the standard UNI EN ISO 9001:2015

DECLARES

under its sole responsibility that the design and the conformity assessment for the

Fig. 340J

Full bore brass ball valve with grooved ends (ANSI/AWWA C606)

nominal size for piping (DN) 32 ÷ 65

maximum allowable pressure (PS)

40 bar up to 95°C and 25 bar at 150°C, for DN ≤ 50

25 bar up to 95°C and 16 bar at 150°C, for DN ≥ 65

suitable for liquid water between 0°C and +150°C

(Ethylene glycol and propylene glycol mixtures up to 50% may be used)

and air between -10°C and +150°C

are in compliance with

Directive 2014/68/EU (PED)

Conformity assessment procedure Module A (Cat. I) for DN ≥ 40

free of CE marking (SEP) according to Art. 4.3 for DN ≤ 32

not suitable for gases and liquids group 1

President
ing. Savino Rizzio