



REFRIGERATION AND
AIR CONDITIONING

Instructions


AK-XM 204A





080R9215




RI8HJ602



080Z0011



AK-XM 204A




-20° < t_{amb} < 55°C
-0°F < t_{amb} < 130°F
0 - 95% RH, non condensing
IP10 / VBG4
UL: E357029



Warning

Ensure power is
disconnected before
adding or removing
Modules


DO x 8



Keep the safety distance
Low and high voltage must
not be connected to the
same output group




Max. 230 V
AC-1: max. 4 A (ohmic)
AC-15: max. 3 A (Inductive)

Danfoss
A80Z29.1.10



	Signal	Active at
DO	Comp 1	ON
	Comp 2	OFF
	Fan 1	
	Alarm	

Address



Signal	Active at	Module	Point	Terminals
			1 (DO 1)	25-26-27
			2 (DO 2)	28-29-30
			3 (DO 3)	31-32-33
			4 (DO 4)	34-35-36
			5 (DO 5)	37-38-39
			6 (DO 6)	40-41-42
			7 (DO 7)	43-44-45
			8 (DO 8)	46-47-48