

Vic™-End II End-of-Run Fitting

No. 67



1.0 PRODUCT DESCRIPTION

Available Sizes

- 1 ¼ – 3"/DN32 – DN80 with ½"/DN15, ¾"/DN20 or 1"/DN25 female threaded NPT or BSPT outlet

Pipe Material

- Carbon Steel, Schedule 10, Schedule 40. For use with alternative materials and wall thicknesses, contact Victaulic.

Maximum Working Pressure

- Up to 365 psi/2500 kPa/25 Bar

Function

- End-of-branchline elbow fitting for sprinkler connection

2.0 CERTIFICATION/LISTINGS



EN 10311
CPR (EU)
No. 305/2011

3.0 SPECIFICATIONS – MATERIAL

Housing:

Ductile iron conforming to ASTM A-536, grade 65-45-12, painted Orange Enamel. Ductile iron conforming to ASTM A-395, grade 65-45-15, is available upon special request.

☐ Optional: Hot dipped galvanized.


Outlet: NPT

☐ Optional: BSPT

ALWAYS REFER TO ANY NOTIFICATIONS AT THE END OF THIS DOCUMENT REGARDING PRODUCT INSTALLATION, MAINTENANCE OR SUPPORT.

4.0 DIMENSIONS

No.67









Nominal Size inches DN		C to GE inches mm	C to TE inches mm	Approximate Weight (Each) lb kg
1 ¼ DN32	x ½ DN15	1.875 48	1.38 35	0.6 0.3
	¾ DN20	1.875 48	1.38 35	0.5 0.2
	1 DN25	2 51	1.75 44	0.6 0.3
1 ½ DN40	x ½ DN15	1.875 48	1.5 38	0.7 0.3
	¾ DN20	1.875 48	1.5 38	0.7 0.3
	1 DN25	2 51	1.625 41	0.7 0.3
2 DN50	x ½ DN15	1.875 48	1.75 44	0.7 0.3
	¾ DN20	1.875 48	1.75 44	0.7 0.3
	1 DN25	2 51	1.75 44	0.9 0.4
2 ½ DN65	x ½ DN15	1.875 48	2 51	1.3 0.6
	¾ DN20	1.875 48	2 51	1.2 0.6
	1 DN25	2 51	2 51	1.3 0.6
3 DN80	x ¾ DN20	2 51	2.375 60	2.0 0.9
	1 DN25	2 51	2.375 60	1.9 0.9

5.0 PERFORMANCE

Reference applicable coupling publication for performance, or contact Victaulic for more information.

6.0 NOTIFICATIONS

⚠️ WARNING



- Read and understand all instructions before attempting to install any Victaulic products.
- Always verify that the piping system has been completely depressurized and drained immediately prior to installation, removal, adjustment, or maintenance of any Victaulic products.
- Confirm that any equipment, branch lines, or sections of piping that may have been isolated for/during testing or due to valve closures/positioning are identified, depressurized, and drained immediately prior to installation, removal, adjustment, or maintenance of any Victaulic products.
- Wear safety glasses, hardhat, foot protection, and hearing protection.

Failure to follow these instructions could result in death or serious personal injury and property damage.

7.0 REFERENCE MATERIALS

- [10.64: FireLock EZ™ Style 009V/009N Rigid Coupling](#)
- [I-100: Field Installation Handbook](#)

<p>User Responsibility for Product Selection and Suitability</p> <p>Each user bears final responsibility for determining the suitability of Victaulic products for their end-use application, in accordance with industry standards, project specifications, and Victaulic’s published performance, maintenance, and safety data, as well as all warnings and installation instructions. Nothing in this or any other document, nor any verbal recommendation, advice, or opinion from any Victaulic employee, shall be deemed to alter, vary, supersede, or waive any provision of Victaulic Company’s standard conditions of sale, warranty, installation instructions, or this disclaimer.</p> <p>Installation</p> <p>Always refer to and follow the Victaulic Installation Handbook or installation instructions for the product you are installing. Handbooks are included with each shipment of Victaulic products, providing complete installation and assembly data, and are available in PDF format on our website at victaulic.com.</p> <p>Warranty</p> <p>Refer to the Warranty section of the current Price List or contact Victaulic for details.</p>	<p>Intellectual Property Rights</p> <p>No statement concerning the use of any material, product, service, or design is intended, or should be construed, to grant any license under any patent or other intellectual property right of Victaulic or any of its affiliates, or as a recommendation for the use of such material, product, service, or design in the infringement of any patent or other intellectual property right. The terms “Patented” or “Patent Pending” refer to design or utility patents or patent applications for articles and/or methods of use in the United States and/or other countries. Victaulic and all other Victaulic marks are the trademarks or registered trademarks of Victaulic Company, and/or its affiliated entities, in the U.S. and/or other countries.</p> <p>Note</p> <p>All products bearing a Victaulic trademark are manufactured by Victaulic or to Victaulic specifications. All products are to be installed only in accordance with the applicable Victaulic installation instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.</p>
---	---